



**NOTES FOR REFLECTED CEILING PLAN**

1. THE CONTRACTOR SHALL CAREFULLY STUDY AND COMPARE THE REFLECTED CEILING PLANS WITH THE ELECTRICAL LIGHTING PLANS, WITH THE MECHANICAL SUPPLY, RETURN AND EXHAUST PLANS, AND WITH THE FIRE PROTECTION PLANS, AND SHALL REPORT TO THE COR ANY ERRORS, INCONSISTENCY OR OMISSION THAT IS DISCOVERED.
2. SPRINKLER HEAD LOCATIONS ARE NOT INDICATED ON THE REFLECTED CEILING PLANS. THE CONTRACTOR SHALL INSTALL SUFFICIENT HEADS IN ALL SPACES TO PROVIDE COMPLETE (100%) AUTOMATIC SPRINKLER COVERAGE AS DEFINED IN NFPA STANDARD 13 AND IN THE PROJECT MANUAL, AND AS REQUIRED BY THE VA MEDICAL CENTER'S INSURANCE UNDERWRITER. CONTRACTOR SHALL PROVIDE DRAWINGS SHOWING LOCATIONS OF SPRINKLER HEADS FOR APPROVAL.
3. THE CONTRACTOR SHALL VERIFY THAT ACCESS PANELS OF APPROPRIATE SIZE AND TYPE ARE INSTALLED IN GYPSUM BOARD CEILINGS OR SOFFITS, IN CEVENT PLASTER CEILINGS OR SOFFITS, AND IN OTHER NON-ACCESSIBLE TYPE CEILINGS OR SOFFITS WHERE ACCESS, SERVICE OR ADJUSTMENT TO HVAC, PLUMBING OR ELECTRICAL ITEMS MAY BE REQUIRED. ACCESS PANELS SHALL BE THE FIRE RATED TYPE EQUAL TO THE RATING OF THE CEILING OR SOFFIT IN WHICH THEY OCCUR.
4. ONLY CEILING MOUNTED EXIT LIGHTS ARE SHOWN ON THE REFLECTED CEILING PLANS. SEE THE ELECTRICAL DRAWINGS FOR LOCATIONS OF WALL MOUNTED EXIT LIGHTS. EXIT LIGHTS SHALL MATCH EXISTING MAKE AND MODEL.
5. SEE THE ELECTRICAL DRAWINGS AND/OR THE COMMUNICATIONS DRAWINGS FOR LOCATIONS OF CEILING MOUNTED SMOKE DETECTORS, SPEAKERS, FIRE ALARM DEVICES, ETC.
6. THE CONTRACTOR SHALL ADVISE THE GOVERNMENT AND TENANTS THAT AN 18" MINIMUM VERTICAL CLEARANCE SHALL BE MAINTAINED BETWEEN THE BOTTOM OF THE EXTENDED SPRINKLER HEADS AND THE TOP OF ANY FILES, SHELVING, LOCKERS, ETC., (WHETHER CONTRACTOR OR OWNER FURNISHED). THE CONTRACTOR SHALL ALSO ADVISE THE GOVERNMENT AND TENANTS THAT ITEMS SHALL NOT BE PLACED OR STORED ON TOP OF SUCH SHELVING SO THAT THIS CODE REQUIRED 18" MINIMUM VERTICAL CLEARANCE WILL BE MAINTAINED.
7. WHERE EXISTING LAY-IN CEILINGS ARE REMOVED AND REINSTALLED, THE CONTRACTOR SHALL TAKE CARE NOT TO DAMAGE EITHER THE CEILING TS OR THE GRID. DAMAGED TILES OR GRID SHALL BE REPLACED WITH NEW MATERIAL. THESE NEW MATERIALS SHALL MATCH THE EXISTING IN A UNIFORM MANNER FOR COLOR, TEXTURE, PATTERN, ETC. IF UNIFORMITY CAN NOT BE ACHIEVED, THE CONTRACTOR SHALL REPLACE THE ENTIRE CEILING WITHIN THAT SPACE WITH NEW MATERIAL. THE CONTRACTOR SHALL PROVIDE NEW MATERIAL AS APPROVED BY BOTH GOVERNMENT AND COR.
8. THE CONTRACTOR SHALL PROVIDE ACCESS PANELS IN ALL GYPSUM BOARD CEILINGS AND IN HARD SURFACE SOFFITS SO THAT THE COR CAN INSPECT RATED WALLS. THESE ACCESS PANELS SHALL BE LOCATED AT INTERVALS NOT TO EXCEED 30'-0" ON CENTER, MINIMUM OF ONE PER SPACE, AND IN SUCH MULTIPLE LOCATIONS AS NECESSARY TO VIEW ALL SURFACES OF THE RATED WALLS.

**FINISH NOTES FOR PROJECT**

1. IN AREAS REQUIRING NEW WORK AND PATCHING, EXISTING FINISHES SHOWN IN THE FINISH SCHEDULE AND ON THE PLANS ARE TO BE VERIFIED BY THE CONTRACTOR AND ANY NOTED DISCREPANCIES IMMEDIATELY CALLED TO THE ATTENTION OF THE COR. ALL NEW FLOOR, BASE, WAINSCOT, WALL AND CEILING FINISHES SHALL BE AS SCHEDULED IN ROOM FINISH SCHEDULE AND AS SHOWN ON DRAWINGS, UNLESS OTHERWISE NOTED.
2. FOR EXISTING CEILING PATCHING, WHERE CEILING IS OUT OUT OR PORTIONS REMOVED FOR REMOVAL OF EXISTING OR INSTALLATION OF NEW MECHANICAL, ELECTRICAL AND PLUMBING WORK, DISTURBED PORTION SHALL BE PATCHED TO MATCH THE EXISTING CEILING FINISH BY THE RESPONSIBLE TRADE. UNLESS OTHERWISE NOTED, THE ENTIRE CEILING AREA IS TO BE REPAINTED WHERE CEILINGS ARE GYPSUM BOARD.
3. ALL FREESTANDING COLUMNS IN A ROOM SHALL RECEIVE THE SAME FINISH AS THE ROOM WALL, UNLESS OTHERWISE NOTED.
4. WHERE NEW FINISHES ARE APPLIED TO EXISTING SURFACES, THE EXISTING FINISHES SHALL BE REMOVED AND/OR THE EXISTING SURFACES PREPARED AS REQUIRED TO RECEIVE NEW FINISHES, UNLESS OTHERWISE NOTED, WHERE REQUIRED TO ACCOMMODATE THE NEW FINISHES, THE MECHANICAL, PLUMBING AND ELECTRICAL TRADES SHALL DISCONNECT AND REMOVE THEIR RESPECTIVE DEVICES AND ITEMS FROM THE EXISTING WALL, CEILING AND/OR FLOOR AND RELOCATE TO THEIR FINAL POSITION IN THE NEW CONSTRUCTION. SUCH DEVICES SHALL INCLUDE BUT NOT BE LIMITED TO ELECTRICAL SWITCHES, PANELS, OUTLETS, MECHANICAL THERMOSTATS, GRILLES, PLUMBING FIXTURES, MEDICAL GAS OUTLETS, ETC.
5. WHERE WALL SURFACES ARE PATCHED TO MATCH THE EXISTING, THE NEW FINISH (PAINT, ETC.) SHALL BE APPLIED TO THE NEAREST CORNER OR BREAK IN THE WALL PLANE, UNLESS NOTED OTHERWISE.
6. WHERE EXISTING WALLS ARE TO RECEIVE A NEW FINISH, ANY EXISTING PAINTED ITEMS IN OR ON THE WALL (DOORS, DOOR FRAMES, ELECTRICAL PANELS, ETC.) SHALL BE REPAINTED TO MATCH OR COORDINATE WITH THE NEW FINISH.
7. IN AREAS THAT HAVE AN EXISTING FLOOR FINISH OF QUARRY TILE OR CERAMIC TILE AND ARE NOTED TO RECEIVE A RESILIENT FLOOR TILE, SHEET VINYL OR GUE DOWN CARPET FINISH, THE CERAMIC/QUARRY TILE SHALL BE REMOVED ALONG WITH ANY LOOSE SETTING BED MATERIAL, AND THE AREA SHALL BE LEVELED AS REQUIRED BY THE SPECIFICATIONS WITH CEMENT GROUT IN PREPARATION FOR THE NEW FINISH.
8. IN AREAS THAT HAVE AN EXISTING FLOOR FINISH OF RESILIENT FLOOR TILE OR CARPET AND ARE NOTED TO RECEIVE NEW CERAMIC OR QUARRY TILE FLOOR, THE ADHESIVE SHALL BE REMOVED IN PREPARATION FOR SUCH NEW HARD TILE.
9. PLASTER OR GYPSUM WALLBOARD WALLS IN AN EXISTING BUILDING FROM WHICH VINYL WALL FABRIC IS REMOVED, SHALL BE CLEANED OF ALL ADHESIVE AND A SKIM COAT OF PLASTER APPLIED TO RECEIVE THE NEW FINISH.
10. IN ALL ROOMS SCHEDULED TO RECEIVE NEW FINISHES, EXISTING PLUMBING FIXTURES AND ACCESSORIES SHALL BE TEMPORARILY REMOVED AS REQUIRED TO ALLOW THE NEW FINISH TO EXTEND UNDER OR BEHIND THE FIXTURE OR ACCESSORY.

**NOTES FOR SEISMIC CONDITIONS**

1. REFER TO STRUCTURAL DRAWINGS FOR DESIGN CRITERIA FOR VA SEISMIC DESIGN REQUIREMENTS (H-18-9)
2. PROVIDE 12 GA. (MIN) HANGER WIRES FOR SUPPORT OF 2'-0" x 2'-0" AND 2'-0" x 4'-0" LAY-IN CEILINGS. SPLICES WILL NOT BE PERMITTED IN HANGER WIRES UNLESS SPECIFICALLY APPROVED BY GOVERNING AUTHORITIES.
3. PROVIDE HANGER WIRES WITHIN 8" OF THE ENDS OF ALL MAIN AND CROSS RUNNERS OR AT 1/4" OF LENGTH OF THE END TEE, WHICHEVER IS LEAST AT THE PERIMETER OF THE CEILING AREA.
4. WIRES SHALL NOT ATTACH TO OR BEND AROUND INTERFERING MATERIAL OR EQUIPMENT. PROVIDE TRAPEZE OR OTHER SUPPLEMENTARY SUPPORT MEMBERS AT OBSTRUCTIONS TO MAINTAIN HANGER SPACING. PROVIDE ADDITIONAL HANGERS, STRUTS OR BRACES AS REQUIRED AT ALL CEILING BRACES, SOFFITS OR DISCONTINUOUS AREAS. HANGER WIRES THAT ARE MORE THAN 1 IN 6 OUT OF PLUMB ARE TO HAVE COUNTER-BRACED WIRES. TRAPEZE SUSPENSIONS SHALL BE A MINIMUM OF BACK TO BACK 1 1/4" INCH COLD ROLLED CHANNELS FOR SPANS EXCEEDING 48 INCHES.
5. CEILING GRID MEMBERS MAY BE ATTACHED TO NOT MORE THAN 2 ADJACENT WALLS. CEILING GRID MEMBERS SHOULD BE AT LEAST 1/2" FREE OF OTHER WALLS. IF WALLS RUN DIAGONALLY TO CEILING GRID SYSTEM RUNNERS, ONE END OF MAIN AND CROSS RUNNERS SHOULD BE FREE AND A MINIMUM OF 1/2" CLEAR OF WALL.
6. AT THE PERIMETER OF THE CEILING AREA, WHERE MAIN OR CROSS RUNNERS ARE NOT CONNECTED TO THE ADJACENT WALL, PROVIDE INTERCONNECTION BETWEEN THE RUNNERS AT THE FREE END TO PREVENT LATERAL SPREADING. A METAL STRUT OR A 16 GA. (MIN) WIRE WITH A POSITIVE MECHANICAL CONNECTION TO THE RUNNER MAY BE USED, WHERE THE PERPENDICULAR DISTANCE FROM THE WALL TO THE FIRST PARALLEL RUNNER IS 1'-0" OR LESS. THIS INTERLOCK IS NOT REQUIRED.
7. PROVIDE SETS OF (4) - 12 GA. SPAYED BRACING WIRES ORIENTED 90 DEGREES FROM EACH OTHER AT THE FOLLOWING LOCATIONS:
  - A. PLACE SETS OF SPAY WIRES AT LOCATIONS NOT MORE THAN 6'-0" FROM EACH PERIMETER WALL OR FROM THE EDGE OF VERTICAL CEILING
  - B. PLACE SETS OF SPAY WIRES AT A SPACING NOT MORE THAN 12'-0" ON CENTER
  - C. A COMPRESSION STRUT SHALL BE PROVIDED PER THE DETAILS.
8. THE SLOPE OF THESE WIRES SHALL NOT EXCEED 45 DEGREE FROM THE PLANE OF THE CEILING, AND SHOULD BE TIGHT WITHOUT CAUSING THE CEILING TO LIFT. SPLICES IN BRACING WIRES ARE NOT PERMITTED WITHOUT SPECIAL APPROVAL FROM GOVERNING AUTHORITIES.
9. FASTEN HANGER WIRES WITH NOT LESS THAN 3 TIGHT TURNS, FASTEN BRACING WIRES WITH 4 TIGHT TURNS, MAKE ALL TIGHT TURNS WITHIN A DISTANCE OF 1 1/2" HANGER OR BRACING WIRE. WIRES ATTACHED TO THE STRUCTURE SHOULD BE INSTALLED IN SUCH A MANNER THAT THE DIRECTION OF THE WIRE ALIGNS AS CLOSELY AS POSSIBLE WITH THE DIRECTION OF THE FORCE ACTING ON THE WIRE.
10. SEPARATE CEILING HANGING AND BRACING WIRES AT LEAST 6" FROM ALL UNBRACED DUCTS, PIPES, CONDUIT, ETC. IT IS ACCEPTABLE TO ATTACH LIGHT-WEIGHT ITEMS, SUCH AS A SINGLE ELECTRICAL CONDUIT NOT EXCEEDING 3/4" NOMINAL DIAMETER, TO HANGER WIRES USING CONNECTORS APPROVED BY GOVERNING AUTHORITIES.
11. WHEN DRILLED-IN CONCRETE ANCHORS OR SHOT-IN ANCHORS ARE USED FOR HANGER WIRES, 1 OUT OF 10 MUST BE FIELD TESTED FOR 200 POUNDS IN TENSION. WHEN DRILLED-IN ANCHORS ARE USED FOR BRACING WIRES, 1 OUT OF 2 MUST BE FIELD TESTED FOR 440 POUNDS IN TENSION. SHOT-IN ANCHORS ARE NOT PERMITTED FOR BRACING WIRES. IF ANY SHOT-IN OR DRILLED-IN ANCHOR FAILS, ALL ADJACENT ANCHORS MUST BE TESTED.
12. ATTACH LIGHT FIXTURES TO THE CEILING GRID RUNNERS TO RESIST A HORIZONTAL FORCE EQUAL TO 100% OF THE WEIGHT OF THE FIXTURES.
13. FLUSH OR RECESSED LIGHT FIXTURES AND AIR TERMINALS OR SERVICES WEIGHING LESS THAN 56 POUNDS MAY BE SUPPORTED DIRECTLY ON THE RUNNERS OF A HEAVY DUTY GRID SYSTEM BUT, IN ADDITION, THEY MUST HAVE A MINIMUM OF (2) SLACK SAFETY WIRES ATTACHED AT DIAGONAL CORNERS. 2" x 4" LIGHT FIXTURES SHALL HAVE SLACK SAFETY WIRES AT EACH CORNER. SAFETY WIRES SHALL BE 12 GA. MINIMUM AND SHALL BE ANCHORED TO THE STRUCTURE ABOVE.
14. FIXTURES AND AIR TERMINALS OR SERVICES SUPPORTED ON INTERMEDIATE DUTY GRID SYSTEMS MUST BE INDEPENDENTLY SUPPORTED BY NOT LESS THAN (4) - 12 GA. (MINIMUM) TIGHT WIRES ATTACHED TO THE STRUCTURE ABOVE, LOCATED TO WITHIN 3 INCHES OF THE CORNER OF THE FIXTURE.
15. ALL FLUSH OR RECESSED LIGHT FIXTURES AND AIR TERMINALS OR SERVICES WEIGHING MORE THAN 56 POUNDS MUST BE INDEPENDENTLY SUPPORTED BY NOT LESS THAN (4) - 12 GA. (MINIMUM) TIGHT WIRES ATTACHED TO THE STRUCTURE ABOVE REGARDLESS OF THE TYPE OF CEILING GRID SYSTEM USED.
16. THE 12 GA. WIRES CALLED FOR IN NOTES 14 AND 15 ABOVE, INCLUDING THEIR ATTACHMENT TO THE STRUCTURE ABOVE, MUST BE CAPABLE OF SUPPORTING FOUR TIMES THE WEIGHT OF THE UNIT.
17. SUPPORT SURFACE MOUNTED LIGHT FIXTURES WITH AT LEAST TWO POSITIVE DEVICES WHICH SURROUND THE CEILING RUNNER AND WHICH ARE SUPPORTED FROM THE STRUCTURE ABOVE BY A 12 GA. (MINIMUM) WIRE, SPRING CLIPS OR CLAMPS THAT CONNECT ONLY TO THE RUNNERS ARE NOT ACCEPTABLE.
18. MAIN RUNNERS (CONTINUOUS MEMBERS) SHALL BE ORIENTED IN THE SHORTER DIRECTION OF THE SPACE, IF THE LONGER DIRECTION OF THE SPACE EXCEEDS 12'-0", THE MAIN RUNNERS AT THE FIXED PERIMETER EDGE SHALL BE 12'-0" LONG MINIMUM.
19. A "HEAVY-DUTY" METAL SUSPENSION SYSTEM IS REQUIRED FOR LAY-IN ACOUSTICAL PANEL CEILING SYSTEMS, SEE SPECIFICATIONS.

**FIRE AND/OR SMOKE WALL/PENETRATIONS**

- IN GENERAL, EXISTING RATED WALLS REQUIRED TO EXTEND TO THE UNDERSIDE OF THE DECK OR STRUCTURE, AND NOT SO DOING, SHALL BE EXTENDED AS FOLLOWS:
- A. AT 1 HOUR GYPSUM WALLBOARD PARTITIONS, USE 4" METAL STUDS WITH 5/8" RATED GYPSUM BOARD AT EACH SIDE. REFER TO WALL TYPES FOR STUD SIZE.
  - B. UPON COMPLETION OF THE SMOKE/FIREWALL UPGRADE, PATCH AND REPAIR AND INSTALL NEW WALL, FLOOR AND CEILING FINISHES AS REQUIRED.
- THE CONTRACTOR SHALL NOTE THE EXTENT OF SUCH AREAS AND SHALL VERIFY ALL SUCH AREAS WITH THE CONTRACTING OFFICER REPRESENTATIVE. ANY/ALL ADDITIONAL WORK SHALL BE APPROVED BY THE CONTRACTING OFFICER BEFORE THE CONTRACTOR IS TO PROCEED. THE CONTRACT AMOUNT SHALL THEN BE ADJUSTED TO REFLECT ANY ADDITIONAL REPAIRS AS OUTLINED IN THE GENERAL CONDITIONS OF THE CONTRACT.
1. CONTRACTOR TO SEAL ALL PENETRATIONS THRU RATED WALLS PER THE U.L. ASSEMBLY REQUIRED FOR EACH PARTICULAR TYPE OF PENETRATION (PIPE, CONDUIT, DUCT, ETC.) AND WALL CONDITION (OPP. BR/MTL. STUDS, CONCRETE, ETC.). CONTRACTOR TO PROVIDE DATA SHEETS OF EACH TYPE OF U.L. ASSEMBLY USED. DATA SHEETS TO BE KEPT ON FILE AT JOBSITE. OFFICE DURING CONSTRUCTION FOR THE BUILDING INSPECTOR'S USE. DATA SHEETS TO BE INCLUDED AS PART OF THE CLOSE-OUT DOCUMENTATION AT THE END OF THE PROJECT. SEE THE STANDARD FIRE/SMOKE WALL AND PENETRATION DETAILS SHEETS INCLUDED IN THESE DRAWINGS.
  2. ALL FIRE AND/OR SMOKE RATED PARTITIONS AND CORRIDOR PARTITIONS SHALL EXTEND FROM THE FINISHED FLOOR TO WHERE IT MAY BE SEALED TIGHT, SUCH AS THE UNDERSIDE OF THE STRUCTURE OR DECK ABOVE. ALL PENETRATIONS THROUGH SUCH PARTITIONS SHALL BE SEALED PER THE APPROPRIATE U.L. DETAIL FOR THE WALL RATING DESIGNATED. COORDINATE PROPER SEALING OF HVAC, PLUMBING AND ELECTRICAL ITEMS WITH HVAC, PLUMBING AND ELECTRICAL DRAWINGS AND SHEET A-006 & A-301.
  3. ALL CORRIDOR PARTITIONS SHALL BE MADE SMOKE TIGHT. ALL SUCH PARTITIONS SHALL EXTEND FROM THE FINISHED FLOOR TO WHERE IT MAY BE SEALED TIGHT, SUCH AS THE UNDERSIDE OF THE STRUCTURE OR DECK ABOVE. ALL PARTITIONS AND ANY PENETRATIONS SHALL BE SEALED TIGHT WITH DRYWALL COMPOUND OR SEALANT. RATED WALLS SHALL BE SEALED WITH A U.L. LISTED AND APPROVED FIRESTOPPING ASSEMBLY.
  4. IN NEW CONSTRUCTION OR CONDITIONS REQUIRING EXISTING CONSTRUCTION TO BE REMOVED, ALL PENETRATIONS THROUGH FLOOR SLABS SUCH AS PIPING, CONDUITS, DUCTS, PNEUMATIC TUBES, ETC., SHALL BE PACKED AND SEALED OFF WITH A 2-HR FIRE RATED MATERIAL, IN ACCORDANCE WITH THE APPLICABLE DETAILS. SEE A-006.
  5. EXISTING FIRE/SMOKE WALLS WITHIN THE LIMITS OF CONSTRUCTION SHALL BE INSPECTED TO CORRECT THE FOLLOWING ITEMS:
    - 5.1. PARTITION EXTENDS AND IS TIGHT TO AND SEALED OFF FROM THE BOTTOM OF THE DECK OR STRUCTURE ABOVE AS TYPICALLY DETAILED ON THE DRAWINGS.
    - 5.2. ALL PENETRATIONS AND HOLES THROUGH THE WALLS ARE REPAIRED/PATCHED IN ACCORDANCE WITH THE APPLICABLE DETAILS.
    - 5.3. EXISTING RECESSED MOUNTED ITEMS LARGER THAN 16"x16" INCHES SQUARE, IN RATED PARTITIONS, ARE TO BE ENCASED IN A DOUBLE FIRE WALL OR ENCASED IN 5/8" GYPSUM BOARD ENCLOSURES ON ALL SIDES.
  6. EXISTING PENETRATIONS: EXISTING CONCEALED AREAS SUCH AS CHASES, UNDERSIDE OF FLOORS BELOW EXISTING TOILET/BATHROOM FACILITIES, BELOW EXISTING EQUIPMENT, ETC., WITHIN THE LIMITS OF CONSTRUCTION, SHALL BE EXAMINED BY THE CONTRACTOR DURING THE PROCESS OF CONSTRUCTION. ALL SUCH AREAS HAVING OPEN PENETRATIONS SHALL BE SEALED OFF WITH FIRE RATED MATERIAL AS REQUIRED. THE CONTRACTOR SHALL NOTE THE EXTENT OF SUCH AREAS AND SHALL VERIFY ALL SUCH AREAS WITH THE CONTRACTING OFFICER REPRESENTATIVE. ANY/ALL ADDITIONAL WORK SHALL BE APPROVED BY THE CONTRACTING OFFICER BEFORE THE CONTRACTOR PROCEEDS. THE CONTRACT AMOUNT SHALL THEN BE ADJUSTED TO REFLECT SUCH REPAIRS AS OUTLINED UNDER THE GENERAL CONDITIONS OF THE CONTRACT.
  7. ANY DEVICE LOCATED IN A FIRE AND/OR SMOKE RATED WALL UP TO 16"x16" IN SIZE SHALL BE PROTECTED WITH ONE LAYER OF 5/8" RATED GYPSUM BOARD FOR 1 HOUR WALLS. THE DEVICE SHALL BE COMPLETELY ENCLOSED BY THE GYPSUM BOARD WHICH SHALL BE SCREW ATTACHED TO AUXILIARY DRYWALL FRAMING AS REQUIRED TO PROVIDE THE PROPER SIZE ENCLOSURE. ELECTRICAL BOXES, NOT OVER 16 SQUARE INCHES, MAY BE PROTECTED BY AN APPROVED INTUMESCENT PAD IN LIEU OF BEING BOXED IN WITH GYPSUM WALLBOARD.

**BID DEDUCTS**

NONE

100% SUBMITTAL

BID SET - CONSTRUCTION DOCUMENTS

DATE: DECEMBER, 21 2012

**GENERAL NOTES AND SYMBOLS**

SCALE: NOT TO SCALE

BID SET - 100% CONSTRUCTION DOCUMENTS

FULLY SPRINKLERED

BY	REVISIONS	DATE

**LINDBERGH & ASSOCIATES, LLC**  
 2170 Ashley Phosphate Road - Suite 304  
 Charleston, South Carolina, 29406  
 Phone: (843)553-6670 Fax: (843)553-0755



**CONFIDENTIAL** THESE DRAWINGS MUST BE RETURNED TO FACILITIES MANAGEMENT SERVICE, PROJECT SECTION, UPON COMPLETION, OR FINAL USE BY THE CONTRACTOR FOR BIDDING PURPOSES.

**ASBESTOS WARNING:** ASBESTOS CONTAINING BUILDING MATERIALS (ACBM) ARE PRESENT THROUGHOUT THE FACILITY. IF CONTRACTORS FIND ACBM, OR SUSPECT FINDING ACBM, THEY SHALL IMMEDIATELY STOP WORK AND CONTACT THE PROJECT COR.

**SCALE NOTES:** FULL SIZE VA, T, "S" SHEETS (SCALE AS INDICATED) AND HALF SIZE VA, T, "S" SHEETS (½ THE SCALE INDICATED LETTER)

**GENERAL NOTE:** CONTRACTORS AND ARCHITECT/ENGINEERING FIRMS ARE RESPONSIBLE FOR THE FIELD VERIFICATION OF ALL EXISTING CONDITIONS.

Project Title  
**RENOVATE  
 WARD 5 EAST**

Drawing Title	Date	
GENERAL NOTES	12/21/12	
Building Number	Checked	Drawn
47	JSA	NEK
Location	ASHEVILLE, NC	

Project No.	DRAWING NO.
637-11-119	A-002
Dwg	3 of 78

Office of Facilities  
 Department of Veterans Affairs